

## ADDENDUM No. 2

### PUC SERVICES

2025 WATERMAIN LINING BY CIPP  
WILLOW AVENUE, CHAPPLE AVENUE, STRAND AVENUE  
AND ANITA BOULEVARD  
PUC CONTRACT WDS 20843

March 24, 2025

#### PART 1 - Questions During Tender Period

1. Can PUC clarify whether MJ Adapters can be used? Is there a limit on the maximum amount of valves that can be MJ adapted? ***MJ adapters may be used only on the hydrant branch of a Tee. The contractor cannot use MJ adaptor in mainline runs, as shown on our detail.***
2. Can the PUC clarify the restrained transition coupling process. Can a typical sleeve be used with a set of restraints? ***Couplings are not required. The contractor shall follow PUC specifications using sleeves and appropriate grip rings for material types. No added restraints are required.***
3. Clarification- ***where “spools” are shown on the drawings, it means a stub of appropriate material and sized water main minimum length 0.3m to maximum length 0.5m.***

End of ADDENDUM #2